



KISTNER CONCRETE PRODUCTS INC.
8713 READ ROAD
E. PEMBROKE, N.Y.
14056
(716) 894-2267


PRODUCT DESIGNATION
1800 GALLON LEACHING CHAMBER

DWG. NO.
LC-LC1800

SPECIFICATIONS:
CONCRETE: 4,000 P.S.I. @ 28 DAYS.
ENTRAINED AIR: 5% - 9%.
STEEL: A.S.T.M. A496-A615 GRADE 60-60 KSI.
DESIGN LOADING: A-0.3/300PSF/WALKWAYS.
FLOATION FORCES NOT ACCOUNTED FOR.

EFFECTIVE SIDEWALL ABSORPTION AREA- 209.42 SQ. FT.
THEORETICAL GALLON CAPACITY-1867 GALLON, INT.
VOL.-257.73 CU. FT.

WEIGHT-TOP SECTION -2000 LBS.
BASE SECTION -2000 LBS.
FIRST RISER SECTION -1500 LBS.
SECOND RISER SECTION -1500 LBS.
TOTAL -7000 LBS.



20" DIA. CLEAR OPNG. WITH COVER

